



Chase Ritenauer, Mayor

The City of Lorain, Ohio

INTERIOR POINT OF SALE INSPECTION

Robert Fowler, Safety Director
Richard Klinar, Chief Building Official

Property Address _____	Inspection Date _____
E-mail _____	Inspection# _____
<input type="checkbox"/> LMI <input type="checkbox"/> NON-LMI <input type="checkbox"/> ESCROW	Inspector _____

Note: At time of inspection utilities were on off Lockbox# _____

CODE NO. & DESCRIPTION	PASS	FAIL	COMMENTS
304.13.2 Openable Windows			
304.18.1 Doors			
305.3 Interior Surfaces			
306.1 Handrails & Guardrails (General)			
308.1 Extermination			
504.1 Plumbing Systems & Fixtures			
603.2 Removal of Combustion Products			
603.5 Combustion Air			
604.3 Electrical System Hazards 605.2 Receptacles			
704.1 Fire Protection Systems			
Other:			Miscellaneous Notes:



Chase Ritenauer, Mayor

The City of Lorain, Ohio

EXTERIOR POINT OF SALE INSPECTION

Robert Fowler, Safety Director
Richard Klinar, Chief Building Official

Property Address _____	Date Paid _____
Name _____	Expiration Date _____
Telephone# _____	Inspection Date _____
E-mail _____	Inspection# _____
<input type="checkbox"/> LMI <input type="checkbox"/> NON-LMI <input type="checkbox"/> ESCROW	Inspector _____

Checkmark indicates correction must be made prior to occupancy. Lockbox# _____

CODE NO. & DESCRIPTION	PASS	FAIL	COMMENTS
302.4 Weeds			
302.7 Accessory Structures			
302.8 Motor Vehicles			
304.2 Protective Treatment			
304.3 Premises Identification			
304.7 Roofs and Drainage			
304.10 Stairways, decks, porches and balconies			
304.12 Handrails and Guards			
304.13 Window, skylight, and door frames			
306.1 Handrail and Guardrails (general)			
Other:			Miscellaneous Notes:



Chase Ritenauer, Mayor

The City of Lorain, Ohio

POINT OF SALE INSPECTION

Robert Fowler, Safety Director
Richard Klinar, Chief Building Official

Property Address _____	Inspection Date _____
E-mail _____	Inspection# _____
<input type="checkbox"/> LMI <input type="checkbox"/> NON-LMI <input type="checkbox"/> ESCROW	Inspector: _____

Note: At time of inspection utilities were on off Lockbox# _____

	ADDITIONAL NOTES/VIOLATIONS

CODE DESCRIPTIONS

302.4 Weeds

All premises and exterior property shall be maintained free from weeds or plant growth in excess of 6". All noxious weeds shall be prohibited. Weeds shall be defined as all grasses, annual plants and vegetation, other than trees or shrubs provided; however, this term shall not include cultivated flowers and gardens.

302.7 Accessory Structures

All accessory structures, including detached garages, fences and walls, shall be maintained structurally sound and in good repair.

302.8 Motor Vehicles

Except as provided in other regulations, no inoperative or unlicensed motor vehicles shall be parked, kept or stored on any premises, and no vehicle shall at any time be in a state of major disassembly, disrepair, or in the process of being stripped or dismantled. Painting of vehicles is prohibited unless conducted inside an approved spray booth.

304.2 Protective Treatment

All exterior surfaces, including but not limited to, doors, door and window frames, cornices, porches, trim, balconies, decks, and fences shall be maintained in good condition. Exterior wood surfaces, other than decay-resistant woods, shall be protected from the elements and decay by painting or other protective covering or treatment. Peeling, flaking, and chipped paint shall be eliminated and surfaces repainted. All siding and masonry joints as well as those between the building envelope and the perimeter of windows, doors, and skylights shall be maintained weather resistant and water tight. All metal surfaces subject to rust and corrosion shall be stabilized and coated to inhibit future rust and corrosion. Oxidation stains shall be removed from exterior surfaces. Surfaces designed for stabilization by oxidation are exempt from this requirement.

304.3 Premises Identification

Buildings shall have approved address numbers placed in a position to be plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches high with a minimum stroke width of 0.5 inches.

304.7 Roofs and Drainage

The roof and flashing shall be sound, tight and not have defects that admit rain. Roof drainage shall be adequate to prevent dampness or deterioration in the walls or interior portion of the structure. Roof drains, gutters, and downspouts shall be maintained in good repair and free from obstructions. Roof water shall not be discharged in a manner that creates a public nuisance.

304.10 Stairways, Decks, Porches and Balconies

Every exterior stairway, deck, porch and balcony, and all appurtenances attached thereto, shall be maintained structurally sound, in good repair, with proper anchorage and capable of supporting the imposed loads.

304.12 Handrails and Guards

Every handrail and guard shall be firmly fastened and capable of supporting normally imposed loads and shall be maintained in good condition.

304.13 Window, Skylight and Door Frames.

Every window, skylight, door, and frame shall be kept in sound condition, good repair and weather tight.

308.1 Extermination

All structures shall be kept free from insect and rodent infestation. All structures in which insects or rodents are found shall be promptly exterminated by approved processes that will not be injurious to human health. After extermination, proper precautions shall be taken to prevent reinfestation.

504.1 Plumbing Systems & Fixtures (General)

All plumbing fixtures shall be properly installed and maintained in working order, and shall be kept free from obstructions, leaks, and defects and be capable of performing the function for which such plumbing fixtures are designed. All plumbing fixtures shall be maintained in a safe and sanitary and functional condition.

603.2 Removal of Combustion Products

All fuel-burning equipment and appliances shall be connected to an approved chimney or vent.

603.5 Combustion of Air

A supply of air for complete combustion of the fuel and for ventilation of the space containing the fuel-burning equipment shall be provided for the fuel-burning equipment.

604.3 Electrical System Hazards

Where it is found that the electrical system in a structure constitutes a hazard to the occupants or the structure by reason of inadequate service, improper fusing, insufficient receptacle and lighting outlets, improper wiring or installation, deterioration or damage, or for similar reasons, the code official shall require the defects to be corrected to eliminate the hazard.

605.2 Receptacles

Every habitable space in a dwelling shall contain at least two separate and remote receptacle outlets. Every laundry area shall contain at least one grounded-type receptacle or a receptacle with a ground fault circuit interrupter. Every bathroom shall contain at least one receptacle. Any new bathroom receptacle outlet shall have ground fault circuit interrupter protection.

704.1 Fire Protection Systems (General)

All systems, devices and equipment to detect a fire, actuate an alarm, or suppress or control a fire or any combination thereof, shall be maintained in an operable condition at all times in accordance with the *International Fire Code*.